

NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 14 - CONDEMNED BOILERS OR PRESSURE VESSELS

001. This chapter is adopted pursuant to Neb. Rev. Stat. §48-727.
002. Any boiler or pressure vessel that has been recommended for condemnation shall be immediately discontinued from service.
003. The Department shall be promptly notified of such action and the Chief Inspector or a Deputy Inspector shall reinspect the boiler or pressure vessel for final action.
004. Boilers and pressure vessels that are condemned by the Chief Inspector or a Deputy Inspector shall have distinctly stamped thereon over the State of Nebraska serial number the following symbol, "XXX". In addition to stamping the metal tag a label shall be affixed to the unit showing that the unit has been condemned. If the metal tag is not on the unit a label showing the serial number shall be attached to the unit.
005. Any person, firm, partnership or corporation using or offering for sale a condemned boiler or pressure vessel for operation within this jurisdiction shall be subject to the penalties provided for in the Act.
006. Any unit that has been condemned and then repaired shall be inspected by the Chief Inspector or a Deputy Inspector prior to any operation of the unit. A copy of all of the repair forms shall be presented to the inspector prior to the inspection.